



# *Borough of Totowa*

Fire Prevention Bureau  
537 Totowa Road  
Totowa, New Jersey 07512

Mark Henry  
Fire Official

973 956-1000 ext. 1013  
Fax: (973) 956-8159

## ***VERIFICATION OF TESTING OF EMERGENCY LIGHTING***

Inspected Business's Name: \_\_\_\_\_

Business Address: \_\_\_\_\_

On, \_\_\_\_\_,

The emergency lighting at the above listed premise was tested for one hour in accordance with  
**N.J.A.C. 5:70-3 1203.4**

Testing: Required emergency lighting systems, including exit signs, shall be tested for proper operation for a minimum of 30 seconds every month. An annual test shall be conducted for at least 1 hour. Equipment shall function properly for the duration of the test (recommended testing to be performed by shutting the breaker that supplies power to the light).

**Any and all emergency lights and exit signs not working properly have been repaired and/or replaced.**

Company Conducting Test: \_\_\_\_\_

Company Address: \_\_\_\_\_

Company Phone Number: \_\_\_\_\_

Person Conducting Test: (print) \_\_\_\_\_

Signature of Testing Person: \_\_\_\_\_